

## Declaration of conformity - IP66 rating MC-3200/MC-3200 EX

We hereby declare that the Cavotec Micro-control MC-3200 / MC-3200 EX enclosure is IP66 rated according to IEC 60529. The declaration is based on the following Cavotec Micro-control documents:

- TR-12-025 Test report for environmental testing of MC-3200, report nr. 160937-01
- TN-13-001 DNV-OS-D202 Test-object overview for Terminal-unit

EX marking label states the IP degree after the standard IEC 60079-0 which include conditioning, impact test, drop test in -35°C prior to the IP degree testing according to IEC 60529.

Requirement according IEC 60079-0 is IP54 for group I (Mining) and IP20 for group II (Gas).

6/4-2016

(Place)

Hell

(Date)

Mette Olsen

Mette Olsen

Technical manager

