

Declaration obsolescence of MC-EX-BARRIER

Manufacturer:
(name/address) **Cavotec Micro-control AS**
Gevinglia 112
N-7517 Hell
Norway

Type of equipment: **EX BARRIER**
Type designation: **MC-EX-BARRIER**
Part number: **M9-1040-3001**

From 2011 the MC-EX-BARRIER was obsoleted.
The MC-EX-BARRIER were replaced by MC-EX-BARRIER2.
The MC-EX-BARRIER can be replaced 1:1 with the MC-EX-BARRIER2.

Differences MC-EX-BARRIER vs MC-EX-BARRIER2:

- MC-EX-BARRIER2 is galvanically separated
- MC-EX-BARRIER2 can be placed in zone2/category 3 areas
- MC-EX-BARRIER2 have a lower housing

Other than this the fit, form and function is the same as for MC-EX-BARRIER2.

Hell
.....
(Place)

2020-12-11
.....
(Date of issue)

Pål Solem
(Quality Manager)
Pål Solem
.....
(name and signature of authorized person)